

# ADDENDUM No. 5

FOR THE

## CITY OF DELANO WELL 41 EQUIPPING PROJECT

August 15, 2019



OWNER:  
City of Delano  
1015 Eleventh Avenue  
Delano, CA 93216  
(661) 721-3380

PREPARED BY:  
QK.  
5080 California Avenue, Suite 220  
Bakersfield, CA 93309  
(661) 616-2600

**ADDENDUM No. 5**

The following additions, deletions, or modifications shall become part of the Contract Documents for this Project:

**CONTRACTOR QUESTIONS**

**Q1.** The Motor Control Center / VFD / RVSS Specifications calls out for Seismic Shaker Table Testing as a Requirement (Spec. 26 29 25-2 Part 2.02 C). Would standard 3rd party seismic calculations suffice? (Shaker Table Testing is Typically Only Provided for SFPUC Projects Due to Geographical Location & this is a VERY Expensive Test if Needed)

**A1.** Yes 3<sup>rd</sup> party seismic calculations will suffice, shaker table testing will not be required

**Q2.** SCADA Programming is a Requirement of the Project to be Performed by the System Integrator (Spec. 40 94 43-1 Part 1.04 B). On the call you mentioned that all SCADA programming would be accomplished by Delano (Please Advise)

**A2.** The contractor will handle all of the programming of the PLC and HMI Touchscreen Panel. Once the contractor is done installing the equipment the City will give them the IP addresses to use on this site, the City will configure the radio that the contractor supplies to work on the City network and then integrate it into the City SCADA system.

**Q3.** Specification 40 94 43-3 calls out for a 5 port Stride ethernet switch. Drawing E7 calls out for an 8 port ethernet switch. (Please Advise)

**A3.** 8 port ethernet switch is correct

**Q4.** Drawing E3 & E5 calls out for an 800 Amp ATS (Assumed to be an Error). Single Line Diagrams and Building Overview (E2 & E6) Show 600 Amp

**A4.** 600 amp is correct

**NOTE:** **One copy of this Addendum Number 5 shall be signed by the Contractor and must be submitted with the bid as acknowledgement of receipt and acceptance of this Addendum Number 5.**

Prepared by:   
Rebekah Godett, P.E.  
QK

8/15/19  
Date

Accepted by: \_\_\_\_\_  
Contractor (Signature)

\_\_\_\_\_  
Date

\_\_\_\_\_  
Contractor (Print Name)

\_\_\_\_\_  
Title